


ADDENDUM NO. 1

TO THE DRAWINGS FOR

MIRACLE FIELD

For
The Miracle League
W.F.I.S.D Athletic Complex
Wichita Falls, Texas



SLA PROJECT NO. 0738

PROJECT DATE: January 31, 2008

February 25, 2008

Secord & Lebow Architects, L.L.P.
2004 Quail Creek Drive, Suite 200
Wichita Falls, Texas 76308
Phone (940) 767-7478
Fax (940) 397-0553

ADDENDUM DATE: February 25, 2008

TO: All General Contract Bidders of Record:

The following changes are hereby made a part of the plans, specifications, and bidding documents the same as if therein written.

Acknowledge receipt of this addendum by inserting its number and date in the Contractor's Proposal. Failure to do so may subject Bidder to disqualification. This addendum forms a part of the Contract Documents and modifies them as follows:

- ITEM 1:** Fixture P-1 was scheduled incorrectly and should be an Eljer model 111-2145 floor mounted, ADA compliant toilet with Bemis model 19555SSC seat and Sloan model Regal 111 flush valve with actuator installed on wide side of stall.
- ITEM 2:** **Sheet C-104:** The new 1" Domestic Water Line shown shall be upsized to a 2" Domestic Water Line for it's entire length.

ITEM 3: **Sheet C-104:** The new 3/4" Domestic Water Meter shown shall be upsized to a 2" Water Meter.

ITEM 4: **Sheet IR-1:** The location of the new 2" water meter and 2" D.C.A. to serve the irrigation system shall be installed near Barnett Drive immediately adjacent to the new 2" domestic water meter indicated on sheet C-104 (and revised per item 3 above). A 2" line shall then extend from the 2" irrigation meter to the 1 1/2" irrigation loop and tie in near the southeast corner of the property. Note that this is a separate meter from the domestic line.

END OF ADDENDUM