

REQUEST FOR INFORMATION

NUMBER: 024

DATE: 10-1-09

<p>OWNER: SUBMITTED TO:</p> <p>Scott Campbell SG Development 1500 Waters Ridge Drive Lewisville, Texas 76208</p>	<p>PROJECT NAME:</p> <p>STONEGATE SKILLED NURSING FACILITY OF LAWTON 7502 Quanah Parker Trailway Lawton, Oklahoma 73505 Randy Thomas - Superintendent - 918-760-8053</p>
<p>Stephen L. Jordan - Wayne Watson Stephen L. Jordan and Associates 4189 E. Mission Blvd. Fayetteville, Arkansas Phone: 479.444.9923 Fax: 479.444.9924 E-mail: sjordan@jordanandassociates.com</p>	<p>SUBMITTED BY:</p> <p>Erin Sherman ARTHUR CONSTRUCTION COMPANY, INC 7767 Burkburnett Road Wichita Falls, Texas 76305 Phone: 940.851.0022 Fax: 940.851.8900 Cell: 940.704.9404 Erin@accitexas.com</p>
<p>SUBJECT: Trench Drain</p>	
<p>INFORMATION REQUESTED</p> <p>Trench Drain cut on page P12 -2,show's a Length but Know Width,Need Width so we can get the Grate made</p>	
<p>RESPOND TO: Fax - 940.851.8900 Erin@accitexas.com</p>	
<p>RESPONSE - OWNER/ARCHITECT</p> <p>Per C Section on sheet P-12, the width is 1'-4".</p>	
<p>REQUESTED BY:</p> <p>Erin Sherman ARTHUR CONSTRUCTION COMPANY</p>	<p>ANSWERED BY - ARCHITECT:</p> <p>Wayne Watson Jordan & Associates</p>